

HEA 61/62 Multicontact Auxiliary Relay

Instruction Manual

Manual P/N: 1601-0491-A1 Manual Order Code: GEK-131088







Copyright © 2019 GE Multilin. All rights reserved.

HEA 61/62 Multicontact Auxiliary Relay Instruction Manual.

The contents of this manual are the property of GE Multilin. This documentation is furnished on license and may not be reproduced in whole or in part without the permission of GE Multilin. The manual is for informational use only and is subject to change without notice.

Part number: 1601-0491-A1 (April 2019)

For further assistance

For product support, contact the information and call center as follows: GE Grid Solutions 650 Markland Street Markham, Ontario Canada L6C 0M1 Worldwide telephone: +1 905 927 7070 Europe/Middle East/Africa telephone: +34 94 485 88 54 North America toll-free: 1 800 547 8629 Fax: +1 905 927 5098 Worldwide e-mail: <u>multilin.tech@ge.com</u> Europe e-mail: <u>multilin.tech.euro@ge.com</u> Website: <u>http://www.gegridsolutions.com/multilin</u>

Warranty

GE warrants its GE manufactured HEA products for one year. For warranty details including any limitations and disclaimers, see our Terms and Conditions at

https://www.gegridsolutions.com/multilin/warranty.htm

Manual revision history

This manual, including the GEH-5028L insert, form the full instructions for the HEA61 and HEA62 hand-reset auxiliary relays. See page 3 of the GEH-5028L insert for a complete list of the model covered by these instructions.

Major updates for rev A1:

SECT (A1)	DESCRIPTION
Cover	New product image, colors and branding updated, added CE mark and ISO 90001 logo
Introduction	Added Manual revision history, Contact information, Warranty, Approvals, Cautions and warnings.

Approvals

Compliance	Applicable Directive	According to
CE1	Low Voltage Directive	EN60255-27
UL Recognized		UL508, NKCR2

1. Only applicable for HEA 61 relays

Overvoltage Category:	
Pollution Degree:	
Insulation Class:	Ш



This product does not require special grounding.

Cautions and Warnings

Before attempting to install or use the device, review all safety indicators in this document to help prevent injury, equipment damage, or downtime.

Safety words and definitions

The following symbols used in this document indicate the following conditions



Indicates a hazardous situation which, if not avoided, will result in death or serious injury.



Indicates a hazardous situation which, if not avoided, could result in death or serious injury.



Indicates a hazardous situation which, if not avoided, could result in minor or moderate injury.



Indicates practices not related to personal injury.



Indicates general information and practices, including operational information, that are not related to personal injury.

General cautions and warnings HEA 61/62

- Installation/service personnel must be familiar with general device test practices and electrical awareness, and safety precautions must be followed.
- Before performing visual inspections, tests, or periodic maintenance on this device or associated circuits, isolate or disconnect all hazardous live circuits and sources of electric power to the relay.
- Failure to denergize live sources prior to servicing, commissioning or decommissioning could expose you to dangerous voltages causing injury or death.
- Ensure that all connections to the product are correct so as to avoid accidental risk of shock and/or fire, prior to energizing the system and incoming sources.
- Follow the requirements of this manual, including adequate wiring size, terminal wiring practices, wire type, terminal torque settings, coil voltage to be applied, and adequate isolation of harness and cable routing.
- Use the device only for its intended purpose and application.
- In addition to the safety precautions mentioned, all electrical connections made must respect the applicable local jurisdiction electrical code.
- Ensure that the sources applied to the device, i.e coil voltage input, match the ratings specified on the relay nameplate. Do not apply voltage in excess of the specified limits.
- No wires should enter the top cutout and cross down to the lower side of the relay. In doing this, the wire would be outside the barrier and when the cover is installed, would be pushed in against the shunts and prevent proper action of the moving contact. NO wires can be outside the barrier which could lead to relay failure.
- Never use tape wrapped around the terminal lug and the wire insulation. The tape may in time unwrap and interfere with the contact gap, preventing the relay from proper operation.
- The terminal screws are to be tightened from 15-20 inch-pounds. Exceeding 20 Inchpounds may damage terminal screw and relay contacts.
- The relay must be installed in an enclosure or a panel preventing access to energized hazardous live parts. If installed in the door of a cabinet, the relay must be installed with the provided plastic cover.


GEH-2058L



INSTRUCTIONS

AUXILIARY RELAYS

HAND RESET WITH Target Types HEA61 HEA62



CONTENTS

DESCRIPTION	3
CHARACTERISTIC	3
APPLICATION	4
OPERATING CHARACTERISTICS	4
RATINGS	4
BURDENS	5
CONSTRUCTION AND CIRCUITRY	5
INSTALLATION	5
RECEIVING INSTALLATION AND WIRING PRACTICES MOUNTING CONNECTIONS	5 6 7 7
MAINTENANCE	7
PERIODIC TESTS	7
SERVICING	9
CONTACT CLEANING	9
RENEWAL PARTS INSTALLATION	9
RENEWAL PARTS	9

Since the last edition, a change has been made in item 5 under **MAINTENANCE** <u>PERIODIC TESTS</u>

AUXILIARY RELAYS - HAND RESET

TYPES HEA61 HEA62

DESCRIPTION

The Type HEA relay is a high speed, multi-contact, hand reset, auxiliary relay provided with a mechanical target which indicates whether it is in the tripped or reset position. Table I lists the differences among the various relays covered by these instructions.

TABLE I

MODEL	FIG.	NO. OF CONTACTS SPECIAL FEATURES AND REMARKS
HEA61A HEA61B HEA61C HEA61CRD HEA61CRL HEA61CRR HEA61CRU	6 7 8 8A 8B 8C 8D	6 + 2 FOR TRIP COIL 10 + 2 FOR TRIP COIL 16 + 2 FOR TRIP COIL 17 + 2 FOR TRIP COIL 16 + 2 FOR TRIP COIL 17 + 2 FOR TRIP COIL 16 + 2 FOR TRIP COIL 17 + 2 FOR TRIP COIL 16 + 2 FOR TRIP COIL 17 + 2 FOR TRIP COIL 16 + 2 FOR TRIP COIL 17 + 2 FOR TRIP COIL 16 + 2 FOR TRIP COIL 17 + 2 FOR TRIP COIL 16 + 2 FOR TRIP COIL 17 + 2 FOR TRIP COIL 16 + 2 FOR TRIP COIL 17 + 2 FOR TRIP COIL 16 + 2 FOR TRIP COIL 17 + 2 FOR TRIP COIL 16 + 2 FOR TRIP COIL 17 + 2 FOR TRIP COIL 16 + 2 FOR TRIP COIL 17 + 2 FOR TRIP COIL 18 + 2 FOR TRIP COIL 1
HEA61M HEA61V HEA62A HEA62B HEA62C HEA62CRD HEA62CRL HEA62CRL HEA62CRU	9** 10** 11 12 13 13A 13B 13C 13D	2 + 2 FOR TRIP COIL 14 + 2 FOR TRIP COIL 6 + 2 FOR TRIP COIL 10 + 2 FOR TRIP COIL 16 + 2 FOR TRIP COIL 17 + 2 FOR TRIP COIL 16 + 2 FOR TRIP COIL 17 + 2 FOR TRIP COIL 18 + 2 FOR TRIP COIL 19 + 2 FOR TRIP COIL 19 + 2 FOR TRIP COIL 10

** All HEA62 relays have a diode and resistor incerted across the coil circuit. See Fig. 1B.

These instructions do not purport to cover all details or variations in equipment nor to provide for every possible contingency to be met in connection with installation, operation or maintenance. Should further information be desired or should particular problems arise which are not covered sufficiently for the purchaser's purposes, the matter should be referred to the General Electric Company. To the extent required the products described herein meet applicable ANSI, IEEE and NEMA standards;

To the extent required the products described herein meet applicable ANSI, IEEE and NEAA standards, but no such assurance is given with respect to local codes and ordinances because they vary greatly.

APPLICATION

The Type HEA relays are applicable where it is desired that a number of operations be performed simultaneously. Some of the functions that can be performed by these relays are: trip the main circuit breaker of a system, operate an auxiliary breaker, open a neutral line breaker, trip main and auxiliary field discharge breakers, and operate other relays which, in turn, perform various functions. Another important use of the Type HEA relay is in conjunction with differential relays which protect transformers, rotating apparatus, buses, etc. A typical application is illustrated in Fig. 5.

OPERATING CHARACTERISTICS

The time required to trip the relay from the point of energization of the coil to the closing of the normally open contacts is shown in Fig. 4. The opening time of the normally closed contacts is approximately the same as the closing time of the normally open contacts.

RATINGS

The Type HEA relays are available for all standard coil voltage ratings (intermittent) up to 250 volts DC and 460 volts AC.

The current-closing rating of the contacts is 50 amperes for voltages not exceeding 600 volts. The contacts have a current-carrying capacity of 20 amperes continuously or 50 amperes for one minute. The interrupting rating of the contacts varies with the inductance of the circuit. The values (in amperes) given in Table II, for DC inductive circuits, are based on the average trip coil currents.

CIRCUIT VOLTS	<u>NO</u>	N-INDUCTIVE NUMBER OF		INDUCTIVE CIRCUIT NUMBER OF CONTACTS							
	1 2	IN SERIES	4 IN SERIES	<u>1 2 I</u>	N SERIES	4 IN SERIES					
24 DC 48 DC 125 DC 250 DC 600 DC	6.0 5.0 2.6 0.75 0.25	30.0 25.0 11.0 2.0 0.45	40.0 25.0 8.0 1.35	4.0 3.0 2.0 0.7 0.15	20.0 15.00 6.25 1.75 0.35	30.0 25.0 9.5 6.5 1.25					
115 AC 220 AC 440 AC 550 AC	40.00 25.00 12.00 6.00	50.0 50.0 25.0 12.0		24.0 12.0 5.0 4.0	50.0 25.0 12.0 10.0	40.0 20.0 15.0					

TABLE II CONTACT INTERRUPTION RATING

BURDENS

The burden data of the Type HEA relay is listed in Table III.

		<u>TABLE III</u>	BUI	RDENS	
				MINIMUM RATING (EXTERNAL PRO	TECTIVE RELAY
INTERMITTENT RATING	FREQ	COIL RES. OHMS 25°C	AC INRUSH (CURRENT AMPS)	UNIVERSAL TARGET SEAL-IN (CURRENT AMPS)	SEPARATE TARGET & SEAL-IN (CURRENT AMPS)
12 24 32	DC DC DC	0.4 1.2 2.4		2.0 2.0 2.0	1.0
48 62.5	DC DC DC DC	4.5 7.3 23		2.0 2.0 0.2	1.0 1.0
125 220 250	DC DC	88 103	25	0.2 0.2 2.0	0.2 0.2
115 208 230 460	60 CYC 60 CYC 60 CYC 60 CYC	2.4 9.7 9.7 38.5	14	2.0 0.2	

CONSTRUCTION AND CIRCUITRY

The contact section of this relay is built from parts of the Type SB-1 control and transfer switch (see Fig. 1 and 1A).

The operating shaft is held in the reset position by a positive latch. It is released through the action of the operating coil when it attracts the hinged-armature element.

The mechanical target on the escutcheon plate assembly indicated black when the relay is in the reset position and yellow when in the tripped position. To reset the relay after being tripped, the handle is turned clockwise as indicated by the arrow on the escutcheon plate.

In addition to the 2, 6, 10, 14 or 16 sets of contacts as provided, each relay is equipped with two normally closed contacts connected in series for opening the operating coil circuit.

INSTALLATION

RECEIVING

These relays, when not included as a part of a control panel, will be shipped in cartons designed to protect them against damage. Immediately upon receipt of a relay,

examine it for any damage sustained in transit. If injury or damage resulting from rough handling is evident, file a damage claim at once with the transportation company and promptly notify the nearest General Electric Sales Office.

If the relays are not to be installed immediately, they should be stored in their original cartons in a place that is free from moisture, dust and metallic chips.

INSTALLATION AND WIRING PRACTICES

Careful attention to the wiring and installation of the relay is as important as the proper selection of the relay. Attention to the wiring at the installation and maintaining of the wiring through the life of the relay will result in fewer field problems. The following are recommendations for installation and wiring practices to follow for HEA relays.

The installation of a relay to a panel requires only two items; the holes in the panel for screws and shaft, and the space behind the relay to remove the cover.

The cover should not be removed from the relay during installation to prevent possible damage to shunts and/or latching mechanism.

The front support is designed with cutouts for wires; the top for wires going to fixed contacts, the bottom for wires going to moving contacts. Wiring coming to and from these cutouts should be cabled together by lacing or ties, then clamped to the mounting structure so that no distortion of the switch can occur from tight cables or pulling on the cable.

Covers for relays are available in one size. The standard cover for the HEA relay (4-3/4 inches) is for 24 wires out the top and 24 wires out the bottom. The wire openings are 1-3/4 inches wide by one inch high.

The design of the wire opening is for Type SIS #14 Vulkene insulated switchboard wires (0.150 outside diameter each) General Electric C.I. 57275.

Multiple wires to one terminal should not exceed two #14 wires. When larger than #14 wire is used, a limit of one wire per terminal is recommended. The maximum wire size is #10.

No wires should enter the top cutout and cross down to the lower side of the relay. In doing this, the wire would be outside the barrier and when the cover is installed, would be pushed in against the shunts and prevent proper action of the moving contact. No wires can be outside the barrier width without taking unnecessary risk of relay failure.

The terminal screw is a 10-32 NF2 x 7/16 long binder head, nickle-plated brass screw. The diameter of the head is 13/32 inch. This is the maximum outside diameter of any #10 crimp-type terminal used to terminate wires. When the shank of the crimp-type terminal requires insulation, the type with insulated shanks should be used. Shanks of crimp terminals should be bent slightly up away from the fixed contacts to avoid possibility of gap interference.

Never use tape wrapped around the shank and wire insulation. The tape may eventually unwrap and could possibly position itself in the contact gap preventing the relay from operating properly.

Moving contacts have the terminal screws positioned at 45 degrees and facing away from the relay axis. This position should never be changed at time of installation. The reason for this is that if the moving contact terminal is turned in the opposite direction from which the screw is pointed, the contact will open up and be loose on the hexagon barrier boss. This, in turn, affects the action and gap of the moving contact by stretching the shunt. The terminal should never be changed from the position in which it is received from the factory.

The terminal screws are tightened to 15-20 inch-pounds torque. When applying this torque to tighten the terminal screw on the moving contact, caution should be exercised not to exceed 20 pounds force in the direction the screw is being driven. It is also important that a correct fitting screwdriver be used to prevent relay contact damage and screw head distortion.

MOUNTING

The relay should be mounted on a vertical surface. The relay may be mounted on panels up to two inches thick. If the panel thickness is not specified when ordering, the relay will be furnished for panels up to 3/16 inch thick. The "x 2" after the group number identifies the panel thickness (12HEA61A 224x2). By changing the "x 2" to "x 4" the relay will be suitable for 1/4 inch panel. The number after the "x" equals increments of 1/16 inch, up to 32 for two inches.

The outline and panel drilling diagrams for the various types of HEA relays are shown in Figs. 6 to 13D, inclusive.

CONNECTIONS

The internal connection diagrams for the various types of HEA relays are shown in Figs. 6 to 13D, inclusive. When connecting switchboard wires to the coil circuit, be sure they are kept away from the arc path which occurs when the relay contacts interrupt the coil circuit.

NOTE 1: When connecting wires to all types of switches, excessive thrust must <u>not</u> be applied to the heads of the screws as the switch contacts may become distorted permitting rotation on the switch barrier supports. Likewise the connected wires must not be pulled away from the switch contacts when forming a wiring harness.

NOTE 2: It is also important that a correct fitting screwdriver be used to prevent switch contact damage and screw head distortion.

MAINTENANCE

PERIODIC TESTS

During any scheduled outage of the equipment and preferably at yearly intervals, the relay should be tripped electrically to insure that it is in good operating condition and that all the circuits are complete so that the breakers can be tripped.

Remove cover, visually inspect relay and trip manually by applying force on the armature (Step 7 below).

This electrical test may be performed at 70 percent of rated voltage by inserting the proper value of series resistance in the coil circuit as listed in Table IV being careful to apply the test voltage only long enough to trip the relay.

TABLE IV

VOLTS DC	12	24	32	48	62.5	110	125	220	250
OHM RESIS- TANCE FOR TEST	0.2	0.5	1.0	2.0	3.0	7.0	10.0	38.0	40.0

The following check list gives recommendations to insure the relay functions properly.

- 1. Before installation customer should read this instruction book, GEH-2058. A publication, GET-7293, is also available.
- 2. Check nameplate for correct model number and voltage rating.
- 3. Check for proper coil and resistance (Table III).
- 4. Be sure coil is connected properly using both coil contacts for double break action.
- 5. Each of the coil contacts should have 1/4 inch \pm 1/32" contact gap when open.
- 6. Check that rollers spin freely on latching assembly.
- 7. Relay should trip by hand with a 0.025 shim between armature and pole piece.
- If tripping voltage is too high (should trip at 70 percent of rated voltage), add 0.015 shim (V-6149118) under pole piece, then repeat No. 7.
- 9. Wait 30 seconds between operations for continued operation test.
- 10. In resetting relay, the handle should not be forced against the latch to see if latching has occurred; instead the handle should be released immediately after resetting so you do not prevent or delay tripping.
- 11. Do not try to reset with trip circuit still energized.
- 12. Be sure the wires do not interfere with the latching mechanism and are within outer edges of barriers.
- 13. Be sure tie bolts are tight (25 inch-pounds).

SERVICING

CONTACT CLEANING

For cleaning fine silver contacts, a flexible burnishing tool should be used. This consists of a flexible strip of metal with an etched roughened surface, resembling in effect a superfine file. The polishing action is so delicate that no scratches are left, yet corroded material will be removed rapidly and thoroughly. The flexibility of the tool insures the cleaning of the actual points of contact.

The burnishing tool described is included in the standard relay tool kit obtainable from the factory.

RENEWAL PART INSTALLATION

To remove the moving contact, position the relay so that the contact is open. Remove binding head screw and round head screw (Fig. 2) which hold the shunt to the terminal, press in, on the the top of the contact, to release the torque at its lower end (Fig. 3) and pull the contact upward and off.

The moving contact has a shoe that is assembled between the contact spring and the contact. When assembling a new moving contact, the end of the moving contact support must be inserted between the shoe and the moving contact. Then the contact may slide down into place and the screws may be replaced. When replacing the round head screw be sure the lockwasher is replaced and be careful to avoid creasing the thin metal strips of the shunt. Operate the relay and observe whether the contacts meet squarely and simultaneously. The contacts can be adjusted by bending slightly with smooth faced pliers. After adjustment there should be a 1/32 inch minimum gap, with the contacts closed, between the moving contact and the moving contact support (Fig. 2).

Damage to a fixed contact requires replacement of the complete assembly of fixed contacts and support. Remove screws, change assemblies and replace screws. Check alignment of contacts.

To remove a defective coil, disconnect the leads from contacts, then remove staked screw in bottom of pole piece. Slide coil from under guard and armature being careful not to lose shim under pole piece. Remove pole piece and position in replacement coil. Position shim under pole piece and slide coil assembly under armature and guard. Replace screw and re-store. Check new coil per Items 3 through 12 on check list.

When cams, barriers, moving contact supports, etc., need to be replaced, it is recommended that the relay be returned to the factory for repair and return.

RENEWAL PARTS

It is recommended that sufficient quantities of renewal parts be carried in stock to enable the prompt replacement of any that are worn, broken or damaged.

When ordering renewal parts, address the nearest Sales Office of the General Electric Company, specifying the quantity required and describing the parts.




Fig. 1 (8031895) Six Contact HEA61 Relay in Tripped Position, with Cover Removed




Fig. 1A (8028243) Type HEA62 with Diode-Resistor Board




Fig. 2 (6507946-2) Typical Section Showing Operation of Cams - Front View




Fig. 3 (8918418) Removing and Replacing Moving Contact




Fig. 4 (0127A9510-1) Typical Time-voltage Characteristics of Type HEA61 Relay






Fig. 5 (0165A7690-0) Typical Application of Type HEA Relays as Auxiliary Device in the Differential Protection of a Generator



			RELAY FORM NUMERAL													CONTACT					
CYC	LES	DC	DC	DC	DC	DC	DC	DC	DC	50	60	25	50/ 60	50 60	25	50 60	DC	DC		ARRAN RESET P	GEMENT
VOL														460	115	208				OPEN	CLOSED
																350				NONE	1 TO 6
	•	211	221	231	241	251	261	271	281	291	301	311	321	331	341	351	361	371		1	2 TO 6
E	-	212	222	232	242	252	262	272	282	292	302	312	322	332	342	352	362	372	 Γ	1 & 2	3 TO 6
MODE																353				I TO 3	4_T0_6
																354				1_TO 4	
		215	225	235	245	255	265	275	285	295	305	315	325	335	345	355	365	375		I TO 5	6
		216	226	236	246	256	266	276	286	296	306	316	326	336	346	356	366	376		 1 TO 6	NONE






INTERNAL CONNECTIONS

NOTE: CONTACTS 7 & 8 SHOWN IN RESET POSITION

Fig. 6 (0165A7675-4) Outline, Panel Drilling and Internal Connections for HEA61A Relay



INTERNAL CONNECTIONS

NONE

NOTE-CONTACTS II & 12 SHOWN IN RESET POSITION.

Fig. 7 (0165A7676-3) Outline, Panel Drilling and Internal Connections for HEA61B Relay

420 440

1 TO 10






Fig. 8 (0165A7677-4) Outline, Panel Drilling and Internal Connections for HEA61C Relay





TOP

Ð

PANEL DRILLING (FRONT VIEW)

33 4

32 3

ī

I

DIA. 8

HANDLE END OF SWITCH

BOTTOM CONNS .-


-TOP CONNS.7

DIA. ų

(3 HOLES)


1				CONTACT								
CYCLES	DC	DC	DC	DC	DC		50/G		DC		ARRANG RESET	EMENT POSITION
VOLTS	250	125	48	24	220	115	460	230	275		OPEN	CLOSED
	210	230	250	270	290	310	330	350	370		NONE	1 TO 16
A	211	231	251	271	291	311	331	351	371		I	2 TO 16
a l	212	232	252	272	292	312	332	352	372		112	3 TO 16
1 de la	213	233	253	273	293	313	333	353	373	-	1 TO 3	4 TO 16
HEAGIC	214	234	254	274	294	314	334	354	374	ļ	1 TO 4	5 TO 16
보	215	235	255	275	295	315	335		375		1 TO 5	6 T 0 16
2	216	236	256	276	296	316	336	356	376		I TO G	7 TO 16
	217	237	257		297	317	337	357	377		1 TO 7	B TO 16
MODEL	218	238	258	278	298	318	338	358	378		I TO 8	9 TO 16
Ĭ	219	239	259	279	299	319	339	359	379		I TO 9	10 TO 16
ļ	220	240	260	280	300	320	340	360	380	2	I TO 10	11 TO 16
	221	241	261	281	301	321	341		381	ļ	ITOH	12 TO 16
	222	242	262	282	302	322	342	362	382		1 TO 12	13 TO 16
•	223	243	263	283	303	323	343	363	383		I TO 13	14T0 16
	224	244	264	284	304	324			1384		1 TO 14	15T0 16
		5 24-5				325			5385		I TO 15	16 16
	226	5 246	266	286	5300	326	346	366	386	5	1 TO 16	NONE
L	1224	1270	1-01		1000	1	0-70	1000	1-0-			

Fig. 8A (0195A9035-1) Outline, Panel Drilling and Internal Connections for Relay HEA61CRD




TOP

				CONT	ACT								
CYCLES	DC	DC	DC	DC	DC	50/6 0			DC		ARRANGI RESET	EMENT Position	
VOLTS	250	125	48	24	220	115	460	230	275		OPEN	CLOSED	
	210	230	250	270	290	310	330	350	370		NONE	1 TO 16	
1.1	211	231	251	271	291	311	331	351	371			2 70.16	
CR	212	232	252	272	292	312	332	352	372		1 # 2	3 1016	
5	213	233	253	273	293	313	333	353	373		1 103	4 T 0 6	
∢	214	234	254	274	294	314	334	354	374		I TO 4	5 T 0 1 6	
H	215	235	255	275	295	315	335	355	375		1 TO 5	6 TO 16	
2	216	236	256	276	296	316	336	356	376		1 TO G	7 TO 16	
	217	237	257	277	297	317	337	357	377		1 10 7	8 1016	
MODEL	218	238	258	278	298	318	338	358	378		1 TO 8	9 7 0 16	
Ī	210	239	259	279	299	319	339	359	379		<u> TO 9</u>	10 TO 16	
	220	240	260	280	300	320	340	360	380		1 1 0 10	11 TOIG	
	221	241	261	281	301	321	341	361	381		1 1011	12 TO 16	
	222	242	262	282	302	322	342	362	382		1 T012	13 TO 16	
	223	243	263	283	303	323	343	363	383		1 + 013	14 TO 16	
									384		1 + 014	15 TO 16	
	225	24	265	285	305	325	5 345	365	385		1 TO15	1616	
	226	246	266	286	306	326	346	366	386		1 1016	NONE	




HANDLE END OF SWITCH




INTERNAL CONNECTIONS NOTE-CONTACTS 17E18 SHOWN IN RESET POSITION.


Fig. 8B (0195A9033-1) Outline, Panel Drilling and Internal Connections for Relay HEA61CRL



				CONT	ACT						
CYCLES	DC	DC	DC	DC	DC	50/60			DC	ARRANG RESET	
VOLTS	250	125	48	24	220	115	460	230	275	OPEN	CLOSED
	210	230	250	270	290	310	330	350	370	NONE	1 TO 16
α	211	231	251	271	291	311	331	351	371	1	2 TO 16
AGICRR	212	232	252	272	292	312	332	352	372	11.2	3 TO 16
1	213	233	253	273	293	313	333	353	373	1 TO 3	4 TO 16
Ă	214	234	254	274	294	314	334	354	374	I TO 4	5 TO 16
U I	215	235	255	275	295	315	335	355	375	I TO 5	GT0 16
2	216	236	256	276	296	316	336	356	376	1 TO 6	7 T O 16
1	217	237	257	277	297	317	337	357	377	I TO 7	8T0 16
MODEL 12	518	238	258	278	298	318	338	358	378	I TO 8	9T0 16
1 X	219	239	259	279	299	319	339	359	379	I TO 9	IOTO 16
	220	240	260	280	300	320	340	360	380	1 TO 10	11 TO 16
	221	241	261	281	301	321	341	361	381	I TO II	1270 16
	222	242	262	282	302	322	342	362	382	I TO 12	13T0 16
		243				323				1 TO 13	14T0 16
						324				I TO 14	15 TO 16
	225	245	265	285	305	325	345	365	385	I TO 15	16 16
	226	246	266	286	306	326	346	366	386	1 T O 16	NONE




HANDLE END OF SWITCH




INTERNAL CONNECTIONS NOTE-CONTACTS 17 6 18 SHOWN IN RESET POSITION

Fig. 8C (0195A9034-1) Outline, Panel Drilling and Internal Connections for Relay HEA61CRR



TOP

					CONTACT								
CYCLES	DC	DC	DC	DC	DC	50/60 00					ARRANGEMENT RESET POSITI		
VOLTS	250	125	48	24	220	115	460	230	275		OPEN	CLOSED	
	210	230	250	270	290	310	330	350	370		NONE	I TOIG	
3	211	231	251	271	291	311	331	351	371			2 TO 16	
AGICRU	212	232	252	272	292	312	332	352	372		1 4 2	3 TO16	
Ĭ	213	233	253	273	293	313	333	353	373		1 TO 3	4 T 016	
¥.	214	234	254	274	294				374		I TO 4	5 TOIO	
μ	215	235	255	275	295	315	335	355	375		1 TO 5	6 7016	
121	216	236	256	276	296	316	336	356	376		1 70 6	7 7016	
	217	237	257	277	297	317	337	357	377		1 70 7	8 TO16	
MODEL	218	238	258	278	298	318	338	358	378		1 10 8	9 10 10	
Ξ	210	235	259	279	299	319	339	359	379		1 10 9	10 TO 10	
						320					<u>1 T 0 10</u>	II TOK	
	221	24	261	281	301	321	34	361	381		ITOII	12 TO 10	
	222	242	262	282	2 302	322	2 34	2362	382		I T012	13 TO 10	
						323			383		1 +013	14 TO 10	
	224	244	264	1284	1304	1324	1344	1364	384		1 1014	15 TO 10	
	22	24	5 265	5 285	305	5 325	5 34.	5365	5 385		I T015	1616	
									538e		17016	NONE	




(↓ DIA. (3 HOLES)

DIA.


TAP

PANEL DRILLING (FRONT VIEW)




INTERNAL CONNECTIONS NOTE-CONTACTS 17818 SHOWN IN RESET POSITION.

Fig. 8D (0195A9036-0) Outline, Panel Drilling and Internal Connections for Relay HEA61CRU




Ī	RELAY FORM NUMERAL											CONTACT ARRANGEMENT						
CYCLES		DC	DC	DC	DC	DC	DC	DC	DC	50	/60	25	DC	50 60	DC		RESET	POSITION
VOLTS		250	125	48	24	60	32	12	220	115	230	230	110	460	275		OPEN	CLOSED
MODEL		10	20	30	40	50	60	70	80	90	100	110	120	130	140		334	NOME
2HEAGIN		11	21	31	41	51	61	71	81	91	101	111	121	131	141		3	¥.
		12	22	32	42	52	62	72	82	92	102	112	122	132	142		NONE	3 & 4





INTERNAL CONNECTIONS

NOTE-CONTACTS 5 & 6 SHOWN IN RESET POSTTIONS.

Fig. 9 (0165A7681-2) Outline, Panel Drilling and Internal Connections for HEA61M Relay









OUTLIKE

			REL	AY.	CONTACT						
CYCLES	DC	DC	DC	DC	50%		DC		ARRANGEMENT		
VOLTS	250	125	48	24	115	230	220		OPEN	CLOSED	
	10	30	50	70	90	10	130		NONE	1 TO 14	
	11	31	51	71	91	111	131		1	2 TO 14	
	12	32	52	72	92	112	132		162	3 TO 14	
	13	33	53	73	93	113	133		1703	4 TO 14	
2	14	34	54	74	94	114	134		1 104	5 TO 14	
9	15	35	55	75	95	115	135		1 TO 5	6 TO 14	
	16	36	56	76	96	116	136		1 706	7 TO 14	
2HE	71	37	57	77	97	117	137		1 70 7	8 TO 14	
21	18	38	58	78	98	118	138		1 TO 8	9 TO 14	
	19	39	59	79	99	119	139		1 TO 9	10 TO 14	
L. 10	20	40	60	80	100	120	140		1 10 10	11 70 14	
ă	21	41	61	81	101	121	141		1 TO 11	12 TO 14	
MoDe	22	42	62	82	102	122	142		1 TO 12	13 To 14	
4	23	43	63	83	103	123	143		1 TO 13	14	
	24	44	64	84	104	124	144		1 7014	NONE	




INTERNAL CONNECTIONS MOTE: CONTACTS 15 & 16 SHOWN IN RESET POSITION.

Fig. 10 (0165A7686-2) Outline, Panel Drilling, and Internal Connections for Relay HEA61V



HANDLE END OF SWITCH








Fig. 11 (0178A7111-4) Outline, Panel Drilling and Internal Connections for HEA62A Relay



NOTE - CONTACTS 11 & 12 IN RESET POSITION.



INTERNAL CONNECTIONS

NOTE - CONTACTS 17 & 18 SHOWN IN RESET POSITION.

Fig. 13 (0178A7113-4) Outline, Panel Drilling and Internal Connections for HEA62C Relay




Fig. 13A (0246A2251-1) Outline, Panel Drilling and Internal Connections for Relay HEA62CRD




Fig. 13B (0246A2252-1) Outline, Panel Drilling and Internal Connections for Relay HEA62CRL




Fig. 13C (0246A2253-1) Outline, Panel Drilling and Internal Connections for Relay HEA62CRR




Fig. 13D (0246A2250-1) Outline, Panel Drilling and Internal Connections for Relay HEA62CRU

GE Grid Solutions 650 Markland Street Markham, Ontario Canada L6C 0M1

Worldwide telephone: +1 905 927 7070 Europe/Middle East/Africa telephone: +34 94 485 88 54 North America toll-free: 1 800 547 8629 Fax: +1 905 927 5098

Worldwide e-mail: <u>multilin.tech@ge.com</u> Europe e-mail: <u>multilin.tech.euro@ge.com</u> Website: <u>http://www.gegridsolutions.com/multilin</u>

